

ENVIRONMENTAL WATER PRIVATE LIMITED

**St. Antony's
A.M.A EAGLE'S WATER SUPPLY
Dodathogur, Bangalore-560100**

From,
Environmental water pvt ltd
#31,3rd cross of Mahalaxmi layout,
Indranagar

To,
Praveen Kumar.A
AMA EAGLE WATER SUPPLY
Bangalore

RAW WATER QUALITY REPORT

Sample ID / Reference	<u>Rwqr/001/24/25</u>
Sampling Date	06-10-2025
Report Date	<u>08/10/2025</u>
Location / Source	<u>Vittasandra</u>
Collector / Operator	_____

1. Test Results

Parameter	Reference Standard	BIS Limit / Acceptable	Measured Result	Conformance
Color	IS 3025 (Pt. 4)	≤ 15 Units	< 5 TCU	Pass
Odour	IS 3025 (Pt. 5)	Agreeable	Agreeable	Pass
Taste	IS 3025 (Pt. 8)	Agreeable	Agreeable – C	Pass
pH	IS 3025 (Pt. 11)	6.0 – 8.5	7.15	Pass
TDS	IS 3025 (Pt. 16)	≤ 2000 mg/L	220 mg/L	Pass

2. Observations & Comments

All measured parameters lie within the permissible limits prescribed by BIS. The water is clear, tasteless, odorless, with neutral pH and low TDS, indicating good raw water quality. No deviations or anomalies were detected.

